



Tag Time - Newcastle
87 Elder Street-Lambton-2299
INSPECTION & TEST REPORT
3 Phase

Job Address
87 Elder Street Lambton Contact
Tony

TAGTIME
Newcastle
"You're Safe"

3 Phase			Model.	Work Desc.	Service	Test	Insp	Tested By	Freq	Last Service	Date Due
Item ID	Item	Make	Serial No.								
Workshop											
Main Workshop			<i>6 Items</i>								
2677	Pederstile Drilling High Risk	Scruttons	PH031		Test & Tag	PASSPASS	STS2024	3	14 Nov 08	12 Feb 09	
							Darren	Monthl			
2678	Pederstile Drilling High Risk	K & W	T9 21683		Test & Tag	PASSPASS	STS2024	3	14 Nov 08	12 Feb 09	
							Darren	Monthl			
2737	Extension Lead High Risk	Black	5m		Test & Tag	PASSPASS	STS2024	3	14 Nov 08	12 Feb 09	
							Darren	Monthl			
2738	Welder High Risk	Nertazip	540	CUT IN LEAD 4M FROM PLUG DANGER TAG	Failed 1st test	Test & Tag	FAIL FAIL	STS2024	3	14 Nov 08	12 Feb 09
							Darren	Monthl			
2745	Extension Lead High Risk	Black	5m		Test & Tag	PASSPASS	STS2024	3	14 Nov 08	12 Feb 09	
							Darren	Monthl			
2746	Extension Lead High Risk	Black	15m		Test & Tag	PASSPASS	STS2024	3	14 Nov 08	12 Feb 09	
							Darren	Monthl			



Tag Time - Newcastle
87 Elder Street-Lambton-2299
INSPECTION & TEST REPORT
Electrical Equipment

Job Address
87 Elder Street Lambton Contact
Tony

TAGTIME
Newcastle
"You're Safe"

Electrical Equipment

Item ID	Item	Make	Model. Serial No.	Work Desc.	Service	Test	Insp	Tested By	Freq	Last Service	Date Due
Office											
Kitchen											
<i>2 Items</i>											
2799	Toaster	Breville	Beamer		Test & Tag	PASSPASS	STS5762	Barry	1	12 Nov 08	12 Nov 09
		High Risk	797098-0						Yearly		
2800	Microwave	Panasonic	Pure Heat		Test & Tag	PASSPASS	STS5762	Barry	1	12 Nov 08	12 Nov 09
		High Risk	WD09889						Yearly		
Work Station 3											
<i>2 Items</i>											
2739	Power Board	HPM	10amp		Test & Tag	PASSPASS	STS5762	Barry	2	12 Nov 08	12 Nov 10
		Medium Risk	APP1029						Yearly		
2639	computer	Asus	DF-650-T		Test & Tag	PASSPASS	STS5762	Barry	5	12 Nov 08	11 Nov 13
		Low Risk	W98770						Yearly		
Workshop											
Main Workshop											
<i>6 Items</i>											
2532	Pedestal Fan	Ebony	DF-650-T	Lead Out Of Plug-Refit Plug	Failed 1st test	Test & Tag	PASSPASS	STS5762	3	12 Nov 08	10 Feb 09
		High Risk						Barry	Monthl		
2559	Extension Lead	Yellow	6m		Test & Tag	PASSPASS	STS5762	Barry	3	12 Nov 08	10 Feb 09
		High Risk							Monthl		
2560	Extension Lead	Yellow	8m		Test & Tag	PASSPASS	STS5762	Barry	3	12 Nov 08	10 Feb 09
		High Risk							Monthl		
2568	Angle Grinder	Makita	9565C		Test & Tag	PASSPASS	STS5762	Barry	3	12 Nov 08	10 Feb 09
		High Risk	52804 E						Monthl		
2569	Angle Grinder	Bosch	GWS10-125C	Bad Cuts In Lead Moulded Plug-Replace Plug	Failed 1st test	Test & Tag	PASSPASS	STS5762	3	12 Nov 08	10 Feb 09
		High Risk	400026					Barry	Monthl		
2591	Extension Lead	Yellow	8m		Test & Tag	PASSPASS	STS5762	Barry	3	12 Nov 08	10 Feb 09
		High Risk							Monthl		



Tag Time - Newcastle
87 Elder Street-Lambton-2299
INSPECTION & TEST REPORT
Emergency Lighting

Job Address
87 Elder Street Lambton Contact
Tony

TAGTIME
Newcastle
"You're Safe"

Emergency Lighting

Item ID	Item	Make	Model. Serial No.	Work Desc.	Service	Test	Insp	Tested By	Freq	Last Service	Date Due
Office											
Corridore											
			<i>2 Items</i>								
3025	Emergency Light	Minitronics	spitfire CC0987		Time Test 1.5hrs	PASSPASS	STS2024	Darren	6 Monthl	14 Nov 08	15 May 09
3026	Emergency Light	Minitronics	spitfire CC09998		Time Test 1.5hrs	PASSPASS	STS2024	Darren	6 Monthl	14 Nov 08	15 May 09
Front Door											
			<i>1 Items</i>								
3023	Exit Light	Badic	2X10W Flour BD8679		Time Test 1.5hrs	PASSPASS	STS2024	Darren	6 Monthl	14 Nov 08	15 May 09
Rear Door											
			<i>1 Items</i>								
3024	Exit Light	Badic	2X10W Flour BD8688	Replaced 10w tube	Failed 1st test	Time Test 1.5hrs	PASSPASS	STS2024 Darren	6 Monthl	14 Nov 08	15 May 09



Tag Time - Newcastle
87 Elder Street-Lambton-2299
INSPECTION & TEST REPORT
Fire Equipment

Job Address
87 Elder Street Lambton Contact
Tony

TAGTIME
Newcastle
"You're Safe"

Fire Equipment Item ID	Item	Make	Model. Serial No.	Work Desc.	Service	Test	Insp	Tested By	Freq	Last Service	Date Due
Office											
Kitchen 1 Items											
F30	Fire Extinguisher	Exelgard	2A:40B:E	Installed New	Test & Tag 2.5kg	PASSPASS	STS2024	Darren	6 Monthl	25 Nov 08	26 May 09
Workshop											
East Workshop 1 Items											
2503	Fire Hose Reel	GUELL			Level 1 30m	PASSPASS	STS2024	Darren	6 Monthl	12 Nov 08	13 May 09
North Workshop 1 Items											
2505	Fire Extinguisher	Wormald	5-B:C		Level 1 6-38kg	PASSPASS	STS2024	Darren	6 Monthl	12 Nov 08	13 May 09
Paint Shed 1 Items											
2512	Fire Extinguisher	Fire Box	5B:E	Relocated to Paint Shed fitt new signs & brackets	Level 1 9-2kg	PASSPASS	STS2024	Darren	6 Monthl	25 Nov 08	26 May 09
South Workshop Spare 1 Items											
2513	Fire Extinguisher	Exelgard	6A:80B:E		Level 1 13-3kg	PASSPASS	STS2024	Darren	6 Monthl	12 Nov 08	13 May 09
South Workshop Top of Stairs 1 Items											
2517	Fire Blanket	OTFP			Level 1 1m x 1m	PASSPASS	STS2024	Darren	6 Monthl	12 Nov 08	13 May 09
West Workshop 1 Items											
2506	Fire Extinguisher	BFI	5B:E	Fitt New Type Sign	Level 1 15-1kg	PASSPASS	STS2024	Darren	6 Monthl	25 Nov 08	26 May 09



Tag Time - Newcastle
87 Elder Street-Lambton-2299
INSPECTION & TEST REPORT
Hard Hat

Job Address
87 Elder Street Lambton Contact
Tony

TAGTIME
Newcastle
"You're Safe"

Hard Hat Item ID	Item	Make	Model. Serial No.	Work Desc.	Service	Test	Insp	Tested By	Freq	Last Service	Date Due
Workshop											
Gues Hat			<i>4 Items</i>								
3087	Hard Hat	MSA	Type 1 77856		Inspection	N/A PASS	STS2024	Darren	6 Monthl	14 Nov 08	15 May 09
3088	Hard Hat	MSA	Type 1 77857		Inspection	N/A PASS	STS2024	Darren	6 Monthl	14 Nov 08	15 May 09
3089	Hard Hat	MSA	Type 1 77858	replaced sweat band	Inspection	N/A PASS	STS2024	Darren	6 Monthl	14 Nov 08	15 May 09
3090	Hard Hat	MSA	Type 1 77859	replaced sweat band	Inspection	N/A PASS	STS2024	Darren	6 Monthl	14 Nov 08	15 May 09



Tag Time - Newcastle
87 Elder Street-Lambton-2299
INSPECTION & TEST REPORT

Job Address
87 Elder Street Lambton Contact
Tony

TAGTIME
Newcastle
"You're Safe"

Ladder

Ladder Item ID	Item	Make	Model. Serial No.	Work Desc.		Service	Test	Insp	Tested By	Freq	Last Service	Date Due
Workshop												
Main Workshop												
			<i>2 Items</i>									
2997	Ladder	Olfield High Risk	6ft step CC2768	Missing Rubber foot	Failed 1st test	Inspection	N/A FAIL	STS2024	Darren	6 Monthl	25 Nov 08	26 May 09
2998	Ladder	Olfield High Risk	6Mtr CC2726			Inspection	N/A PASS	STS2024	Darren	6 Monthl	25 Nov 08	26 May 09



Tag Time - Newcastle
87 Elder Street-Lambton-2299
INSPECTION & TEST REPORT

Job Address
87 Elder Street Lambton Contact
Tony

TAGTIME
 Newcastle
 "You're Safe"

RCD

RCD	Item	Make	Model. Serial No.	Work Desc.	Service	Test	Insp	Tested By	Freq	Last Service	Date Due
Workshop											
Main Workshop											
			10 Items								
2599RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				21ms			Barry	Monthl		
2611RCD	RCD Box Test	Clipsal	RCBM216/30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				18ms			Barry	Monthl		
2756RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				22ms			Barry	Monthl		
2766RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				23ms			Barry	Monthl		
2787RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				24ms			Barry	Monthl		
2788RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				23ms			Barry	Monthl		
2789RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				22ms			Barry	Monthl		
2794RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				21ms			Barry	Monthl		
2795RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				18ms			Barry	Monthl		
2796RCD	RCD Box Test	Clipsal	485P4CB30		Time Test	PASSPASS		STS5762	3	12 Nov 08	10 Feb 09
	High Risk				26ms			Barry	Monthl		
	TOTAL		46 Items								