



**Electrical Equipment
Risk Assessment**

Tag Time - Newcastle
87 Elder Street Lambton Contact
Tony

TAGTIME
Newcastle
"You're Safe"

AS3760 / Assessment	Risk	Test Type	Cat.	Environment Factors	Date	Assessed By	Assess Company
Office							
<u>General Office</u>							
As per AS 3760	Medium	Test	2y		17- 3-07	88411C	TAG TIME
	Circuit RCD Protected		NO	This environment includes equipment that is not permanently plugged in and will be moved from time to time or may be on wheels increasing the risk of mechanical damage. Some power boards do not have a switch for each outlet and is likely that equipment will be plugged into it without electrical isolation.			
<u>Kitchen</u>							
As per AS 3760	High	Test	1y		17- 3-07	88411C	TAG TIME
	Circuit RCD Protected		YES	Equipment in this area is often flexed and unplugged it is subject to burns in cables and is being used close to wet areas. Equipment with elements is subject to constant stress and prone to fail electrical testing.			
<u>Work Stations</u>							
As per AS 3760	High	Test	5y		17- 3-07	88411C	TAG TIME
	Circuit RCD Protected		NO	Equipment specifically used in work stations such as computers and printers are unlikely to be unplugged and are not subject to mechanical damage. this area does not have RCD protection. We recommend retesting at 5 yearly intervals as per AS3760			
Workshop							
<u>Workshop</u>							
As Assessed	High	Test	3m		17- 3-07	88411C	TAG TIME
	Circuit RCD Protected		YES	Equipment used in the workshop area is subject to a high risk of mechanical damage from welding & grinding spatter with exposed to heat & metallic dust fragments. Previous testing indicated a higher than average fail rate so we recommend increasing the test intervals from 6mthly to 3 myhly.			
TOTAL 4	Locations						